

# Fire Pre Plan

					<b>ID:</b>
<b>ADDRESS:</b>					
118 Pacific Avenue South					
<b>Email:</b>		<b>Phone:</b>		<b>FAX:</b>	
		642-4441			
<b>Contacts:</b>					
Bob & Judy Andrew 642-4218 Home, 360-244-2081 Cell; Lupida Rodriques-Perez, Manager 642-7043					
<b>Assigned Inspector:</b>		<b>Business License Number:</b>		<b>Occupancy Zone:</b>	
				C1	
<b>National Grid:</b>		<b>Assessor Parcel Number:</b>		<b>Assessed Value:</b>	
<b>Map Page:</b>		<b>Construction Type:</b>		<b>Occupancy Type:</b>	
		Vb		Business	
<b>Roof Type:</b>		<b>Roof Type Material:</b>		<b>Roof Type Construction:</b>	
Wood Truss		Comp.			
<b>Number of Units:</b>		<b>Occupancy Load:</b>		<b>Year Built:</b>	
1		60+		1900's	
<b>Property Use:</b>			<b>Time Normally Occupied:</b>		
Bakery			02:00-20:00		
<b>Building Status:</b>			<b>Critical Infrastructure:</b>		
Occupied					
<b>Notes:</b> Overhand above Sidewalk on Pacific Avenue					
<b>Fire Alarm Panel Location:</b>			<b>Master Key Location:</b>		
None			None		
<b>Gas/LPG Shutoff Location:</b>			<b>Electrical Panel Location:</b>		
NE Corner			See Diagram		
<b>FD Connections:</b>			<b>Sprinkler Room Location:</b>		
None			None		
<b>Other Location Information:</b>			<b>Basement Present:</b>		
			No		
<b>Building Height:</b>	<b>Number of Floors:</b>	<b>Square Feet:</b>	<b>Length:</b>	<b>Width:</b>	
20"	1	37,000	87'	48'	
<b>Water Supply Info:</b>	Hydrant #1, Bolstad and Oregon Avenue, 1,140 GPM; Hydrant #2, Bolstad and Pacific Avenue; Hydrant #3, 3rd Street South and Oregon Avenue, 1,140 GPM				
<b>Exposure Info:</b>	First Place Mall to the north, with CMU Wall; Funland to the South, 20' 2nd steet in between.				
<b>Hazmat:</b>	500 Gallon and 200 Gallon Propane tanks on the East Side.				
<b>Building Access:</b>	Three entrances, one set of double doors on Pacific Avenue. Two Access points from the rear of the building, one double door leading to the north half, a single door leading to the South Half.				
<b>Access Problems:</b>	Shouldn't be any real problem with access, other than 2nd street in narrow.				
<b>Ventilation Problems:</b>	This is actually two buildings, tied together in the front 1/2. Venting one ridgeline may not affect the other buildings.				
<b>Pre-Fire Plan Notes:</b>					
<b>Fire Protection Systems:</b>	None.				
<b>Attachment Comments:</b>					

