



NO.	DESCRIPTION
1	2" GATE VALVE
2	FORD STAINLESS STEEL DOUBLE STRAP SADDLE (OR APPROVED EQUAL)
3	2" GALV. NIPPLE
4	2" GALV. 90° ELL
5	D.I. CL. 52 SUPPLY MAIN (SIZE AS DETERMINED BY FIRE FLOW REQUIREMENTS)
6	90° BEND (MJ X MJ) WITH MEGALUG ADAPTER
7	CONCRETE THRUST BLOCK (SIZE TO BE APPROVED BY CITY)
8	PIPE SLEEVE

NOTES:

1. AFTER SYSTEM IS TESTED, PURITY SAMPLES WILL BE TAKEN AT ALL RISERS IN SYSTEM

CITY OF LONG BEACH			
RISER DETAIL			
APPROVED:			DWG. NO.
BY CITY		DATE	RISER
DATE: 8/96	DRWN: J.H.	CHKD: T.J.O.	SCALE: NONE